

State of California

AIR RESOURCES BOARD

Executive Order G-70-14-D

Relating to the Modification of the Certification of the  
Red Jacket Aspirator Assist Service Station  
Phase II Vapor Recovery System

Pursuant to the authority vested in the Air Resources Board (ARB) by Health and Safety Code Section 41954; and

Pursuant to the authority vested in the undersigned by Health and Safety Code Sections 39515 and 39516;

IT IS ORDERED AND RESOLVED: That the certification issued on December 29, 1978, for the Red Jacket aspirator assist, phase II vapor collection and disposal system licensed to and marketed by Wylain, Incorporated, Red Jacket Pumps Division, is hereby modified to allow:

1. the use of the Red Jacket uphill eductor system on underground vapor return piping with insufficient slope back to the underground storage tank;
2. the use of the Red Jacket overhead hose retractor system, without recirculation trap, as an alternate dispenser configuration;
3. the installation of vapor recovery hoses longer than eight feet at non-retail outlets which fuel special vehicles provided that
  - a. The non-retail outlet fuels special vehicles such as large trucks, large skip loaders, off-the-road equipment, etc. where reaching the fill pipe requires longer hoses, and
  - b. The vapor return hose length is no longer than required, and
  - c. The vapor return hoses are arranged to be self-draining or provisions are made to drain the hoses after each refueling or the system incorporates an ARB approved liquid blockage detection system arranged to cease dispensing when a blockage occurs, and
  - d. the owner or operator of the non-retail outlet demonstrates to the satisfaction of the Executive Officer of the Air Resources Board compliance with conditions b and c above;
4. the option of not using anti-recirculation devices on noncommercial dispensers not subject to Weights and Measures dispenser accuracy requirements; and

5. greater flexibility in the selection of product hose length for each dispenser, provided that the product hose length selected provides for full extension of the vapor hose.

The system hereby modified is certified to be at least 95 percent effective with manifolded vents for attendant/self serve use and at least 90 percent effective with nonmanifolded vents for attendant/self serve use at gasoline service stations in conjunction with Phase I vapor recovery systems which have been certified by the Air Resources Board. The system is described in Exhibits 1, 2, 3, and 4 attached hereto.


IT IS FURTHER ORDERED AND RESOLVED: That compliance with the applicable certification requirements and rules and regulations of the Division of Measurement Standards, the State Fire Marshal's Office, and the Division of Industrial Safety of the Department of Industrial Relations is made a condition of this certification.

IT IS FURTHER ORDERED AND RESOLVED: That the system certified hereby shall perform in actual use with the same effectiveness as the certification test system. Compliance with the applicable performance criterion shall be a condition of this certification, and failure to meet this criterion shall constitute grounds for revocation, suspension, or modification of this certification.

IT IS FURTHER ORDERED AND RESOLVED: That any alteration to the equipment, parts, design, or operation of the system certified hereby, is prohibited, and deemed inconsistent with this certification, unless such alteration has been approved by the undersigned.

IT IS FURTHER ORDERED AND RESOLVED: That except for those non-retail outlets refueling special vehicles, in order for vapor return hoses longer than specified in this certification to be used, the system shall incorporate a liquid blockage detector which is acceptable to the undersigned.

Executed at Sacramento, California, the 16<sup>th</sup> day of May, 1979.



Thomas C. Austin  
Executive Officer

Notes to Accompany Exhibits 1, 2, 3, and 4



Executive Order G-70-14-D

1. One-inch or larger branch lines connecting to a two-inch return pipe are required.
2. Each vapor hose shall be located such that the center line of the hose fitting, at the swivel mounting at the dispenser housing, is not more than 3-1/2 inches above the top surface of the island, and is as close to the surface of the island as possible. *(Does not apply to Exhibit 4.)*
3. For dispenser islands greater than 5 feet in width, each vapor hose length shall not be longer than the sum of one-half the dispenser island width, in feet, plus 6 feet. *(Does not apply to Exhibit 4.)*
4. Product hoses ~~one foot or more longer than the vapor hose~~ shall be ~~installed~~ length shall be selected for each dispenser to provide for full extension of the vapor return hose. *(Does not apply to Exhibit 4.)*
5. State Fire Marshal approved swivels (and offsets if necessary) for this system shall be selected and installed on hoses to prevent hose kinking.
6. *For only those non-retail outlets which fuel special vehicles, the installation of vapor recovery hoses longer than eight feet are allowed provided the following conditions are met:*
  - a. *The non-retail outlet fuels special vehicles such as large trucks, large skip loaders, off-the-road equipment, etc. where reaching the fill pipe requires longer hoses.*
  - b. *The vapor return hose length is no longer than required.*
  - c. *The vapor return hoses are arranged to be self-draining or provisions are made to drain the hoses after each refueling or the system incorporates an approved liquid blockage detection system arranged to cease dispensing when a blockage occurs.*
  - d. *The Executive Officer of the Air Resources Board has approved the plans for compliance with conditions b and c.*
7. *For those dispensers classified as non-commercial by the Division of Measurement Standards and are not required to be tested and sealed by Weights and Measures officials, the use of recirculation traps is optional. However, the use of recirculation traps is recommended by the Division of Measurement Standards in any installation where the user utilizes the gallonage figures.*

EXHIBIT 1

Executive Order G-70-14-D

Red Jacket Aspirator Assist Service Station  
Phase II Vapor Recovery System



## EXHIBIT 2

Executive Order G-70-14- D

Red Jacket Aspirator Assist Service Station

Phase II Vapor Recovery System

### Component List

Item	Manufacturer and Model	State Fire Marshal Identification Number	Substitute Equipment	
			Manufacturer and Model	State Fire Marshal Identification Number
1. Modulating Valve	Red Jacket 188 - 185	GVRC002:001:1		
2. Aspirator, without fluid by-pass tubing	Red Jacket 104 - 016	GVRC002:001:2		
3. Vapor Check Valve	Red Jacket 188 - 184	GVRC002:001:3		
4. Vapor Screen	Red Jacket 176 - 032	GVRC002:001:4		
5. Nozzle, unleaded	OPW-7VE-49	GVRC-002:008:17		
Nozzle, leaded	OPW-7VE-36	GVRC-002:008:15		
Nozzle, unleaded	OPW-7VE-47	GVRC-002:008:16		
Nozzle, leaded	OPW-7VE-34	GVRC-002:008:14		
6. Vapor Return Hose	5/8 in. I.D. by 8 ft.			
7. Recirculation Trap*	OPW-78*	GVRC-002:008:12*		
8. Swivels				
Vapor Hose	State Fire Marshal Approved. 0.495 in. I.D. Minimum			
9. <i>Eductor System</i> <i>(For vapor return piping with insufficient slope, see Exhibit 3.)</i>				
<i>Eductor</i>	Red Jacket 141-182	GVRC:002:001:13		
<i>Pressure Relief Valve</i>	Red Jacket 144-073	GVRC:002:001:14		
<i>Liquid Check Valve</i>	Red Jacket 088-129	GVRC:002:001:18		
<i>Liquid Tank</i>	Red Jacket 081-055	GVRC:002:001:16		
10. <i>Overhead Retractor</i> <i>(Optional, see Exhibit 4)</i>	Red Jacket 171-057	GVRC:002:001:17		

---

\* Not required for overhead dispensers, see Exhibit 4.

Exhibit 3

Executive Order G-70-14-D

Red Jacket Aspirator Assist Service Station  
Phase II Vapor Recovery System

Uphill Eductor System Installation

(for vapor return lines with less than 1/8 inch per foot down slope from dispenser to product tank.)




Exhibit 4  
Executive Order G-70-14-D

Red Jacket Aspirator Assist Service Station  
Phase II Vapor Recovery System  
Alternate Dispenser Configuration  
Red Jacket Overhead Hose Retractor System

FLUID HOSE LENGTH: 12 Feet

VAPOR HOSE LENGTH: As needed to permit natural drainage into dispenser and still avoid kinking when fully extended

VAPOR HOSE DIAMETER: 5/8" inside diameter.

RETRACTOR REEL: Ametek, Aero-Motive, Searle, or approved equivalent. State Fire Marshal Identification Number GVRC:002:001:17

CABLE LENGTH: 10 Feet

RECIRCULATION TRAP: None

SWIVELS: 360° in-line on each end of both fluid and vapor hose. State Fire Marshal Approved 0.495 in. I.D. minimum.

INSTALLATION DIMENSIONS:

